

# Glass and Glazing Federation

Certifies that

*Hanita Coatings.*

Certificate No: ***TC 0303***

100 micron Silver Safety Film (R12122T) has passed Class 2B2  
of BS EN 12600 'Glass in Building – Pendulum  
Test – Impact Test Method and Classification  
For Flat Glass' on 4mm Float Glass

Tested at Wintech Engineering Ltd, UKAS accredited Test Laboratory, No.2223


Issued: ***17 March 2006***

Chief Executive:



N Rees

Director of Glazing:



S H Rice



Glass and Glazing Federation

Glass and Glazing Federation  
44 – 48 Borough High Street  
London  
SE1 1XB  
Tel: 020 7207 5872  
Fax: 020 7357 7458

Test Facility:  
WINTECH Engineering Ltd  
Halesfield 2  
Telford TF7 4QH  
Tel: 01952 586580  
Fax: 01952 586585